



**ADDENDUM NO. 2
INVITATION FOR BID
2026-012
KITSAP COUNTY**

TO: All Respondents

FROM: Glen McNeill. Purchasing Supervisor

CLOSING DATE: 04/08/2026 @2:00 pm

REF NO.: 2025-012 Gordon Field Synthetic Turf Replacement

DATE: 04/06/2026

This second addendum to RFP **2025-012 Gordon Field Synthetic Turf Replacement** is to make clarifications to addendum 1.

Clarification to Addendum 1

5)

- c. Sand must not be used as a performance infill, but sand is allowable for other uses (cooling agent, ballast, etc.). Sands with silica content are subject to the following conditions:
 - i. The **Site-Specific Safety Plan** must address inhalation of silica dust
 - ii. The sand must be rounded, treated, or otherwise dust-suppressed to manage risk of player inhalation of silica dust
 - iii. The **Synthetic Turf Maintenance Documentation** must detail procedures and Personal Protective Equipment (PPE) to manage potential inhalation of silica dust
- d. non-performance infill must be addressed in the **Synthetic Turf Cover** shop drawings. Internal containment methods are allowable so long as they create no impact or tripping hazards. If using solid rubber or other latex-derived materials, identify mitigation and maintenance procedures to minimize risk of exposure for sensitive individuals.

END OF ADDENDUM NO. 2